

REQUEST FOR INFORMATION
Freedom of Information Law
Effective January 1, 1978

Town Use Only: ____ # of copies
\$ ____ Amount

To: Town Clerk, Town of Dryden
93 East Main Street, Dryden, New York 13053

I HEREBY APPLY: (check one)

 X To inspect the following records *as electronic files.*
 For copies of the following records at a cost of \$.25 per page:

Records Description:

CORRESPONDENCE, REPORTS, PHOTOS, AND ANY LEGAL FINDINGS
REGARDING THE PROPERTY AT 5 FREESE ROAD SINCE
APRIL 1, 2011.

I understand that the Town of Dryden has five (5) days to act on this request, and if approved, an additional ten (10) days to provide the requested material.

SIMON ST. LAURENT
Printed Name

1259 DRYDEN ROAD
Address

[Signature]
Signature

Address

Representing

1 THACA, NY 14850
City, State, ZIP

TOWN USE ONLY		
Date Received: <u>8/25/11</u>	APPROVED <input checked="" type="checkbox"/>	DENIED _____ for the reason(s) checked below
<input type="checkbox"/> Confidential Disclosure	<input type="checkbox"/> Part of Investigatory Files	
<input type="checkbox"/> Unwarranted Invasion of Personal Privacy	<input type="checkbox"/> Exempted by Statute Other than FOIL	
<input type="checkbox"/> Other (specify) _____		
<u><i>[Signature]</i></u> Signature	<u>CEO</u> Title	<u>8/26/11</u> Date

NOTICE: Should your request be denied, you have thirty (30) days in which to file an appeal with the Records Access Officer of the Town of Dryden, who must fully explain his/her reasons for such denial in writing within seven (7) days of receipt of an appeal.



Planning Department

93 East Main Street
Dryden NY 13053

T 607 844-8888 ext 216
F 607 844-8008
joy@dryden.ny.us

<http://dryden.ny.us/planning-department>

NOTIFICATION OF STORMWATER VIOLATION

Nickolas Bellisario
41 Oak Brook drive
Ithaca, NY 14850

The following violation(s) of the requirements of the Town of Dryden Local Law #4: Stormwater Management, Erosion & Sediment Control and have been noted by visual inspection of an inspector at the property owned or occupied by you and located at:

Dryden Rd/Freese Rd Intersection, Tax Parcel #53.-1-3.4
SWPPP 015-2009


VIOLATION: Improperly placed and maintained erosion and sediment control measures: silt fencing has failed; silt fencing located less than 10 feet from toe of slope.

REMEDY: Properly grade sloped side of fencing to prevent/minimize roll down. Repair fencing as necessary.

A violation of the Local Law is an offense punishable by a fine not exceeding \$100.00 or by imprisonment for a period not exceeding 15 days or both. Each day's continued breach shall constitute a separate, additional violation. This matter shall be turned over to the Dryden Town Court for failure to respond to this notice within five (5) days.

Please respond to the Town of Dryden Zoning Planning Department at 93 East Main Street, Dryden, NY 13053 or phone 607-844-8888, ext 216. Our staff is available 8:00 AM to 5:00 PM Monday-Friday. Thank you for your cooperation.

Date July 12, 2011


Building Inspector/ Zoning Officer

